

BRE Global
Watford, Herts
WD25 9XX

T +44 (0)1923 664100
E enquiries@breglobal.com
W www.bre.co.uk/global

Halers Lighting Ltd.
Sywell Aerodrome
Sywell
Northampton
NN6 0BT

bre

For the attention of Mr. Tony Allison

19 December 2011

Our Ref. CC261898 let 2 issue 2

Dear Tony

Fire performance of Halers Lighting Ltd. downlights when mounted in ceilings to timber floors

With reference to your e-mail of 26 February 2010 and our subsequent discussions, we are pleased to confirm our opinion that if your Halers H2 downlights are mounted in a plasterboard ceiling to a timber floor that has been successfully tested to BS 476 : Part 21: 1987 or BS EN 1365-1: 1999 for 30 minutes, 60 minutes or 90 minutes then the fire performance of the floor and ceiling would not be affected significantly.

The test evidence and justification for this opinion is given in our report CC 261898B issue 2 which should be considered and accepted by the relevant approval authority before the product is installed.

Yours sincerely,



Norman J. Macdonald
Principal Consultant
For and on behalf of BRE Global
Telephone: 01923 665026
Email: macdonaldn@bre.co.uk